

TYPE CERTIFICATE



Czech

Registration number 11.613.262

issued for the manufacturer/importer:

airRoxy Sp. z o.o.
ul. Graniczna 40
44-178 Przystowice
Poland

Company Registration No.: 242773980

for the product:

Name:	Fan				
Type desig.:	aRc	pRemium	pRestige	pRim,	aRid
Modification:	S	S, TS, PS, HS	S, TS, PS, HS, MS	S, TS, PS, HS	S, TS, HS

Place of the production: Made in P.R.C.

at which the certification has been conducted pursuant to ISO/IEC 17067 – scheme 3 certification scheme in accordance with TUV SUD Czech certification system. The results are stated in Evaluation report file No. 11.612.697 from 26.04.2018.

The product type mentioned above fulfils the applicable requirements of the following regulations/standards which were the basis for its evaluation:
 EN 60335-2-80:2003+A1:04+A2:09, EN 60335-1:2012+AC:14+A11:14 +A13:17,
 EN 55014-1:2017, EN 55014-2:2015, EN 61000-3-2:2014, EN 61000-3-3:2013.

This certificate is valid till: **23.05.2023**

Details and validity conditions are stated in the annex which forms an integral part of this Certificate and contains 2 pages.


This certificate is issued on the basis of voluntary certification, and it does not substitute outputs of the authorized or notified body.


Prague, 23.05.2018





Head of the certification body

1. The product specimen was entered for evaluation and type certification on 26.02.2018.
2. The Certificate was issued on the basis of the documents provided by the client:
 - application for the certifying from 17.01.2018
 - undermentioned producing and accompanying technical documentation.
3. The assessment of factory production control was performed at the product manufacturer concentrating on elements ensuring the continuation of product conformity with certification requirements. The results are stated in the Evaluation report of TÜV SÜD Czech - Initial assessment record from 15.11.2017.
4. Detailed technical data characterizing the product type.


	Air flow	Acoustic pressure	Voltage frequency	Motor power	Rev.(1/min.)
aRc Ø100	104 m ³ /h	1m 45dB 3m 42dB	230V, 50Hz	15W	2400±200r/min
aRc Ø120	158 m ³ /h	1m 46dB 3m 44dB	230V, 50Hz	16W	2200±200r/min
aRc Ø150	257 m ³ /h	1m 43dB 3m 41dB	230V, 50Hz	20W	1450±200r/min

	Air flow	Acoustic pressure	Voltage frequency	Motor power	Rev.(1/min.)
pRim Ø100	104 m ³ /h	1m 40dB 3m 39dB	230V, 50Hz	15W	2400±200r/min
pRim Ø120	158 m ³ /h	1m 46dB 3m 44dB	230V, 50Hz	16W	2200±200r/min
pRim Ø150	257 m ³ /h	1m 47dB 3m 45dB	230V, 50Hz	20W	1450±200r/min

	Air flow	Acoustic pressure	Voltage frequency	Motor power	Rev.(1/min.)
pRemium Ø100	104 m ³ /h	1m 39dB 3m 38dB	230V, 50Hz	15W	2400±200r/min
pRemium Ø120	158 m ³ /h	1m 46dB 3m 44dB	230V, 50Hz	16W	2200±200r/min
pRemium Ø150	257 m ³ /h	1m 47dB 3m 45dB	230V, 50Hz	20W	1450±200r/min

	Air flow	Acoustic pressure	Voltage frequency	Motor power	Rev.(1/min.)
pRestige Ø100	97 m ³ /h	1m 40dB 3m 39dB	230V, 50Hz	15W	2400±200r/min
pRestige Ø120	126 m ³ /h	1m 46dB 3m 44dB	230V, 50Hz	16W	2200±200r/min
pRestige Ø150	218 m ³ /h	1m 47dB 3m 45dB	230V, 50Hz	20W	1450±200r/min



	Air flow	Acoustic pressure	Voltage frequency	Motor power	Rev.(1/min.)
aRid Ø100	104 m ³ /h	1m 39dB 3m 38db	230V, 50Hz	15W	2400±200r/min
aRid Ø120	158 m ³ /h	1m 46dB 3m 44db	230V, 50Hz	16W	2200±200r/min
aRid Ø150	257 m ³ /h	1m 47dB 3m 45db	230V, 50Hz	20W	1450±200r/min

5. List of important parts of the technical documentation:

- The documentation listed in the Assessment Report Reg. No.11.612.697 from 26.04.2018.

6. Validity Conditions

- The certificate shall apply only to its holder and products and production places mentioned therein.
- The transfer of the certificate by its owner to third parties is inadmissible as well as the use of certificate by third parties.
- TÜV SÜD Czech shall be notified forthwith of any product modifications compared to the certified specimen. This fact may cause the certificate continuation dependent on an additional conformity evaluation.
- TÜV SÜD Czech shall supervise the proper functioning of the Quality System at the manufacturer within a period of twelve month on the basis of a concluded contract about the controlling activity.
- The certificate can be renewed on request.
- The certificate shall only be reproduced complete including all the annexes.
- The right to use TÜV SÜD Czech certification mark was not established to the certificate.
- The certificate holder commits to keep records of all the relevant complaints concerning the conformity of the products with the requirements of regulations and standards and make those records available to the certification body TÜV SÜD Czech.
- Not specified items (advertising, use of certification mark and certificates) are governed by the General Conditions for Product Certification, as amended.

